

Table 2: Radiation exposure of workers at Monju and Fugen

Plant	Attribution	Effective dose level (mSv per person)				Total (Sv/person)	Average effective dose (mSv)	Maximum effective dose (mSv)
		<5	5~10	nothing over 10mSv	total (persons)			
Monju	Power Company	402	0	0	402	0.00	0.0	0.0
	Subcontractor	1,079	0	0	1,079	0.00	0.0	0.0
	<b>Total</b>	<b>1,481</b>	<b>0</b>	<b>0</b>	<b>1,481</b>	<b>0.00</b>	<b>0.0</b>	<b>0.0</b>
Fugen	Power Company	102	0	0	102	0.01	0.1	2.2
	Subcontractor	341	0	0	341	0.04	0.1	3.1
	<b>Total</b>	<b>443</b>	<b>0</b>	<b>0</b>	<b>443</b>	<b>0.05</b>	<b>0.1</b>	<b>3.1</b>

Table 3: Radiation exposure of workers at nuclear fuel fabrication facilities

Plant	Attribution	Effective dose level (mSv per person)				Total (Sv/person)	Average effective dose (mSv)	Maximum effective dose (mSv)
		<5	5~10	>10mSv	total (persons)			
Global Nuclear Fuel-Japan (GNFJ)	Power Company	256	0	0	256	0.01	0.1	1.5
	Subcontractor	146	0	0	146	0.00	0.0	0.1
	<b>Total</b>	<b>402</b>	<b>0</b>	<b>0</b>	<b>402</b>	<b>0.01</b>	<b>0.1</b>	<b>1.5</b>
Mitsubishi Nuclear Fuel (MNF)	Power Company	178	0	0	178	0.00	0.0	0.6
	Subcontractor	63	0	0	63	0.00	0.0	0.0
	<b>Total</b>	<b>241</b>	<b>0</b>	<b>0</b>	<b>241</b>	<b>0.00</b>	<b>0.0</b>	<b>0.6</b>
Nuclear Fuel Industries (Tokai)	Power Company	187	0	0	187	0.02	0.1	1.1
	Subcontractor	71	0	0	71	0.00	0.0	0.2
	<b>Total</b>	<b>258</b>	<b>0</b>	<b>0</b>	<b>258</b>	<b>0.02</b>	<b>0.1</b>	<b>1.1</b>
Nuclear Fuel Industries (Kumatori)	Power Company	127	0	0	127	0.00	0.0	0.2
	Subcontractor	73	0	0	73	0.00	0.0	0.0
	<b>Total</b>	<b>200</b>	<b>0</b>	<b>0</b>	<b>200</b>	<b>0.00</b>	<b>0.0</b>	<b>0.2</b>

Table 4: Radiation exposure of workers at Japan Nuclear Fuel Rokkasho Nuclear Fuel Cycle Facilities

Plant	Attribution	Effective dose level (mSv per person)				Total (Sv/person)	Average effective dose (mSv)	Maximum effective dose (mSv)
		<5	5~10	>10mSv	total (persons)			
Reprocessing Plant	Power Company	1,199	0	0	1,199	0.01	0.0	0.5
	Subcontractor	3,798	0	0	3,798	0.04	0.0	1.8
	<b>Total</b>	<b>4,997</b>	<b>0</b>	<b>0</b>	<b>4,997</b>	<b>0.05</b>	<b>0.0</b>	<b>1.8</b>
Uranium Enrichment Plant	Power Company	181	0	0	181	0.00	0.0	0.8
	Subcontractor	429	0	0	429	0.00	0.0	0.1
	<b>Total</b>	<b>610</b>	<b>0</b>	<b>0</b>	<b>610</b>	<b>0.00</b>	<b>0.0</b>	<b>0.8</b>
Low-level radioactive waste disposal center	Power Company	84	0	0	84	0.00	0.0	0.1
	Subcontractor	261	0	0	261	0.00	0.0	0.0
	<b>Total</b>	<b>345</b>	<b>0</b>	<b>0</b>	<b>345</b>	<b>0.00</b>	<b>0.0</b>	<b>0.1</b>
High level radioactive waste management	Power Company	193	0	0	193	0.00	0.0	0.0
	Subcontractor	800	0	0	800	0.00	0.0	0.0
	<b>Total</b>	<b>993</b>	<b>0</b>	<b>0</b>	<b>993</b>	<b>0.00</b>	<b>0.0</b>	<b>0.0</b>

Table 5: Radiation exposure of workers at Research and Development Facilities

Plant	Attribution	Effective dose level (mSv per person)				Total (Sv/person)	Average effective dose (mSv)	Maximum effective dose (mSv)
		<5	5~10	>10mSv	total (persons)			
Ningyo Toge Uranium Enrichment Prototype Plant	Power Company	71	0	0	71	0.00	0.0	0.0
	Subcontractor	118	0	0	118	0.00	0.0	0.1
	<b>Total</b>	<b>189</b>	<b>0</b>	<b>0</b>	<b>189</b>	<b>0.00</b>	<b>0.0</b>	<b>0.1</b>
Reprocessing facilities (Tokai)	Power Company	360	1	0	361	0.04	0.1	8.4
	Subcontractor	758	6	0	764	0.10	0.1	8.3
	<b>Total</b>	<b>1,118</b>	<b>7</b>	<b>0</b>	<b>1,125</b>	<b>0.14</b>	<b>0.1</b>	<b>8.4</b>
Oarai Waste Management Facility	Power Company	34	0	0	34	0.00	0.0	0.3
	Subcontractor	205	0	0	205	0.00	0.0	0.6
	<b>Total</b>	<b>239</b>	<b>0</b>	<b>0</b>	<b>239</b>	<b>0.00</b>	<b>0.0</b>	<b>0.6</b>