

Table 1: Radiation exposure of workers at nuclear reactor facilities for power generation

Plant	Attribution	Effective dose level (persons)										total mSv	Total (Person Sv)	Average effective dose (mSv)	Maximum effective dose (mSv)
		<5 mSv	5-10 mSv	10-15 mSv	15-20 mSv	20-25 mSv	25-30 mSv	30-35 mSv	35-40 mSv	40-45 mSv	45-50 mSv				
Tomari	Power Company	517	0	0	0	0	0	0	0	0	0	517	0.00	0.0	0.1
	Subcontractor	1,928	0	0	0	0	0	0	0	0	0	1,928	0.03	0.0	0.8
	Total	2,445	0	0	0	0	0	0	0	0	0	2,445	0.03	0.0	0.8
Onagawa	Power Company	506	0	0	0	0	0	0	0	0	0	506	0.01	0.0	0.3
	Subcontractor	2,215	1	0	0	0	0	0	0	0	0	2,216	0.30	0.1	5.5
	Total	2,721	1	0	0	0	0	0	0	0	0	2,722	0.31	0.1	5.5
Higashi Dori	Power Company	276	0	0	0	0	0	0	0	0	0	276	0.00	0.0	0.2
	Subcontractor	925	0	0	0	0	0	0	0	0	0	925	0.04	0.1	2.6
	Total	1,201	0	0	0	0	0	0	0	0	0	1,201	0.04	0.0	2.6
Fukushima 1	Power Company	1,566	90	22	0	0	0	0	0	0	0	1,678	2.13	1.3	14.8
	Subcontractor	11,409	1,393	770	369	112	57	21	26	0	0	14,157	43.78	3.1	38.8
	Total	12,975	1,483	792	369	112	57	21	26	0	0	15,835	45.90	2.9	38.8
Fukushima 2	Power Company	545	0	0	0	0	0	0	0	0	0	545	0.02	0.0	0.7
	Subcontractor	1,527	4	0	0	0	0	0	0	0	0	1,531	0.14	0.1	6.6
	Total	2,072	4	0	0	0	0	0	0	0	0	2,076	0.16	0.1	6.6
Kashiwazaki Kariwa	Power Company	1,209	0	0	0	0	0	0	0	0	0	1,209	0.03	0.0	1.5
	Subcontractor	5,008	5	0	0	0	0	0	0	0	0	5,013	0.82	0.2	8.2
	Total	6,217	5	0	0	0	0	0	0	0	0	6,222	0.85	0.1	8.2
Hamaoka	Power Company	791	0	0	0	0	0	0	0	0	0	791	0.03	0.0	1.4
	Subcontractor	3,827	18	4	1	0	0	0	0	0	0	3,850	0.85	0.2	15.5
	Total	4,618	18	4	1	0	0	0	0	0	0	4,641	0.88	0.2	15.5
Shiga	Power Company	415	0	0	0	0	0	0	0	0	0	415	0.00	0.0	0.2
	Subcontractor	2,308	0	0	0	0	0	0	0	0	0	2,308	0.08	0.0	1.9
	Total	2,723	0	0	0	0	0	0	0	0	0	2,723	0.08	0.0	1.9
Mihama	Power Company	390	0	0	0	0	0	0	0	0	0	390	0.01	0.0	1.1
	Subcontractor	1,710	3	0	0	0	0	0	0	0	0	1,713	0.25	0.1	8.5
	Total	2,100	3	0	0	0	0	0	0	0	0	2,103	0.26	0.1	8.5
Takahama	Power Company	509	0	0	0	0	0	0	0	0	0	509	0.01	0.0	0.8
	Subcontractor	3,067	7	0	0	0	0	0	0	0	0	3,074	0.66	0.2	6.8
	Total	3,576	7	0	0	0	0	0	0	0	0	3,583	0.67	0.2	6.8
Ohi	Power Company	489	0	0	0	0	0	0	0	0	0	489	0.03	0.1	1.0
	Subcontractor	2,356	2	0	0	0	0	0	0	0	0	2,358	0.46	0.2	5.8
	Total	2,845	2	0	0	0	0	0	0	0	0	2,847	0.50	0.2	5.8
Shimane	Power Company	482	0	0	0	0	0	0	0	0	0	482	0.01	0.0	0.7
	Subcontractor	2,753	33	2	0	0	0	0	0	0	0	2,788	1.15	0.4	11.4
	Total	3,235	33	2	0	0	0	0	0	0	0	3,270	1.15	0.4	11.4
Ikata	Power Company	453	0	0	0	0	0	0	0	0	0	453	0.02	0.1	1.2
	Subcontractor	1,605	7	0	0	0	0	0	0	0	0	1,612	0.45	0.3	8.0
	Total	2,058	7	0	0	0	0	0	0	0	0	2,065	0.47	0.2	8.0
Genkai	Power Company	619	0	0	0	0	0	0	0	0	0	619	0.00	0.0	0.6
	Subcontractor	2,830	1	0	0	0	0	0	0	0	0	2,831	0.35	0.1	5.5
	Total	3,449	1	0	0	0	0	0	0	0	0	3,450	0.36	0.1	5.5
Sendai	Power Company	456	0	0	0	0	0	0	0	0	0	456	0.03	0.1	3.5
	Subcontractor	2,844	25	4	0	0	0	0	0	0	0	2,873	1.47	0.5	11.8
	Total	3,300	25	4	0	0	0	0	0	0	0	3,329	1.50	0.5	11.8
Tokai	Power Company	270	0	0	0	0	0	0	0	0	0	270	0.00	0.0	0.0
	Subcontractor	666	0	0	0	0	0	0	0	0	0	666	0.01	0.0	3.1
	Total	936	0	0	0	0	0	0	0	0	0	936	0.01	0.0	3.1
Tokai 2	Power Company	284	0	0	0	0	0	0	0	0	0	284	0.02	0.1	1.7
	Subcontractor	1,265	0	0	0	0	0	0	0	0	0	1,265	0.22	0.2	4.6
	Total	1,549	0	0	0	0	0	0	0	0	0	1,549	0.25	0.2	4.6
Tsuruga	Power Company	319	0	0	0	0	0	0	0	0	0	319	0.01	0.0	0.4
	Subcontractor	1,405	0	0	0	0	0	0	0	0	0	1,405	0.07	0.1	1.6
	Total	1,724	0	0	0	0	0	0	0	0	0	1,724	0.08	0.0	1.6
Commercial Plant Total	Power Company	10,096	90	22	0	0	0	0	0	0	0	10,208	2.36	0.2	14.8
	Subcontractor	49,648	1,499	780	370	112	57	21	26	0	0	52,513	51.13	1.0	38.8
	Total	59,744	1,589	802	370	112	57	21	26	0	0	62,721	53.50	0.9	38.8

Plant	Attribution	Effective dose level (persons)				Total (Person Sv)	Average effective dose (mSv)	Maximum effective dose (mSv)
		<5 mSv	5-10 mSv	>10mSv	Total (persons)			
Monju	Power Co	390	0	0	390	0.00	0.0	0.0
	Subcontractor	988	0	0	988	0.00	0.0	0.0
	Total	1,378	0	0	1,378	0.00	0.0	0.0
Fugen	Power Co	105	0	0	105	0.02	0.2	3.7
	Subcontractor	352	0	0	352	0.09	0.3	4.6
	Total	457	0	0	457	0.11	0.2	4.6

Plant	Attribution	Effective dose level (persons)				Total (Person Sv)	Average effective dose (mSv)	Maximum effective dose (mSv)
		<5 mSv	5-10 mSv	> 10mSv	Total (persons)			
Global Nuclear Fuel Japan GNF-J	Power Co	235	0	0	235	0.01	0.1	1.5
	Subcontractor	159	0	0	159	0.00	0.0	0.0
	Total	394	0	0	394	0.01	0.1	1.5
Mitsubishi Nuclear Fuel (MNF)	Power Co	275	0	0	275	0.00	0.0	0.6
	Subcontractor	59	0	0	59	0.00	0.0	0.0
	Total	334	0	0	334	0.00	0.0	0.6
Nuclear Fuel Industries (Tokai)	Power Co	176	0	0	176	0.02	0.1	1.2
	Subcontractor	39	0	0	39	0.00	0.0	0.0
	Total	215	0	0	215	0.02	0.1	1.2
Nuclear Fuel Industries (Kumatori)	Power Co	130	0	0	130	0.01	0.1	0.6
	Subcontractor	79	0	0	79	0.00	0.0	0.1
	Total	209	0	0	209	0.01	0.0	0.6

Plant	Attribution	Effective dose level (persons)				Total (Person Sv)	Average effective dose (mSv)	Maximum effective dose (mSv)
		(mSv)	5-10 mSv	> 10mSv	Total (persons)			
Reprocessing Plant	Power Co	1,221	0	0	1,221	0.00	0.0	0.3
	Subcontractor	4,552	0	0	4,552	0.04	0.0	2.0
	Total	5,773	0	0	5,773	0.04	0.0	2.0
Uranium Enrichment Plant	Power Co	211	0	0	211	0.00	0.0	0.4
	Subcontractor	395	0	0	395	0.00	0.0	0.1
	Total	606	0	0	606	0.00	0.0	0.4
Low-level Radioactive Waste Disposal Center	Power Co	91	0	0	91	0.00	0.0	0.0
	Subcontractor	248	0	0	248	0.00	0.0	0.0
	Total	339	0	0	339	0.00	0.0	0.0
High-level Radioactive Waste Disposal Management Facility	Power Co	181	0	0	181	0.00	0.0	0.0
	Subcontractor	998	0	0	998	0.00	0.0	0.0
	Total	1,179	0	0	1,179	0.00	0.0	0.0

Plant	Attribution	Effective dose level (persons)				Total (Person Sv)	Average effective dose (mSv)	Maximum effective dose (mSv)
		<5 mSv	5-10 mSv	>10mSv	Total (persons)			
Ningyo Toge Uranium Enrichment Prototype Plant	Power Co	69	0	0	69	0.00	0.0	0.0
	Subcontractor	131	0	0	131	0.00	0.0	0.0
	Total	200	0	0	200	0.00	0.0	0.0
Reprocessing Facilities (Tokai)	Power Co	366	0	0	366	0.02	0.1	3.5
	Subcontractor	801	0	0	801	0.07	0.1	4.1
	Total	1,167	0	0	1,167	0.09	0.1	4.1
Oarai Waste Management Facility	Power Co	33	0	0	33	0.00	0.0	0.0
	Subcontractor	158	0	0	158	0.01	0.0	0.5
	Total	191	0	0	191	0.01	0.0	0.5