

Table 2: Radiation exposure of workers at Monju and Fugen

Plant	Attribution	Effective dose level (mSv per person)					Total (persons)	Collective effective dose (person Sv)	Average effective dose (mSv)	Maximum effective dose (mSv)
		0.1 or less	over 0.1 and up to 1	over 1 and up to 2	over 2 and up to 5	over 5 and up to 10				
Monju	Power Company	279	0	0	0	0	279	0.00	0.0	0.00
	Subcontractor	775	0	0	0	0	775	0.00	0.0	0.00
	Total	1,054	0	0	0	0	1,054	0.00	0.0	-
Fugen	Power Company	107	12	1	0	0	120	0.01	0.1	1.28
	Subcontractor	359	63	19	31	1	473	0.16	0.3	9.50
	Total	466	75	20	31	1	593	0.17	0.3	-

Table 3: Radiation exposure of workers at nuclear fuel fabrication facilities

Plant	Attribution	Effective dose level (mSv per person)					Total (persons)	Collective effective dose (person Sv)	Average effective dose (mSv)	Maximum effective dose (mSv)
		0.1 or less	over 0.1 and up to 1	over 1 and up to 2	over 2 and up to 5	over 5 and up to 10				
Global Nuclear Fuel Japan GNF-J	Power Company	181	4	0	0	0	185	2.00	0.0	0.50
	Subcontractor	105	0	0	0	0	105	0.00	0.0	0.00
	Total	286	4	0	0	0	290	2.00	0.0	-
Mitsubishi Nuclear Fuel (MNF)	Power Company	255	2	0	0	0	257	0.00	0.0	0.3
	Subcontractor	872	1	0	0	0	873	0.00	0.0	0.2
	Total	1,127	3	0	0	0	1,130	0.00	0.0	-
Nuclear Fuel Industries (Tokai)	Power Company	131	1	0	0	0	132	0.00	0.0	0.3
	Subcontractor	0	0	0	0	0	0	0.00	0.0	0.0
	Total	131	1	0	0	0	132	0.00	0.0	-
Nuclear Fuel Industries (Kumatori)	Power Company	192	8	0	0	0	200	0.00	0.0	0.4
	Subcontractor	230	3	0	0	0	233	0.00	0.0	0.2
	Total	422	11	0	0	0	433	0.00	0.0	-

Table 4: Radiation exposure at Japan Nuclear Fuel Rokkasho Nuclear Fuel Cycle Facilities

Plant	Attribution	Effective dose level (mSv per person)					Total (persons)	Collective effective dose (person Sv)	Average effective dose (mSv)	Maximum effective dose (mSv)
		0.1 or less	over 0.1 and up to 1	over 1 and up to 2	over 2 and up to 5	over 5 and up to 10				
Reprocessing Plant	Power Company	1,414	0	0	0	0	1,414	X	X	X
	Subcontractor	5,631	26	0	0	0	5,657	0.01	0.0	0.8
	Total	7,045	26	0	0	0	7,071	0.01	0.0	-
Uranium Enrichment Plant	Power Company	217	5	0	0	0	222	0.00	0.0	0.19
	Subcontractor	709	0	0	0	0	709	0.00	0.0	0.09
	Total	926	5	0	0	0	931	0.00	0.0	-
Low-level radioactive waste disposal center	Power Company	110	0	0	0	0	110	0.00	0.0	0.02
	Subcontractor	237	0	0	0	0	237	0.00	0.0	0.01
	Total	347	0	0	0	0	347	0.00	0.0	-
High-level radioactive waste disposal management	Power Company	186	0	0	0	0	186	X	X	X
	Subcontractor	942	0	0	0	0	942	X	X	X
	Total	1,128	0	0	0	0	1,128	X	X	-

Table 5: Radiation exposure of workers at Research and Development Facilities (JAEA)

Plant	Attribution	Effective dose level (mSv per person)					Total (persons)	Collective effective dose (person Sv)	Average effective dose (mSv)	Maximum effective dose (mSv)
		0.1 or less	over 0.1 and up to 1	over 1 and up to 2	over 2 and up to 5	over 5 and up to 10				
Ningyo Toge Uranium Enrichment Prototype Plant	Power Company	57	0	0	0	0	57	0.00	0.0	0.0
	Subcontractor	167	3	0	0	0	170	0.00	0.0	0.2
	Total	224	3	0	0	0	227	0.00	0.0	-
Reprocessing Facilities (Tokai)	Power Company	298	11	1	0	0	310	0.01	0.0	1.2
	Subcontractor	799	46	8	3	0	856	0.04	0.0	2.5
	Total	1,097	57	9	3	0	1,166	0.05	0.0	-
Oarai waste management facility	Power Company	26	0	0	0	0	26	0.00	0.0	0.0
	Subcontractor	188	0	0	0	0	188	0.00	0.0	0.0
	Total	214	0	0	0	0	214	0.00	0.0	-
Oarai R&D Center Fuel Research Building (North Wing)	Center staff	41	0	1	0	0	42	2 ^{*4}	0.0	1.9
	Other than Center staff	121	3	0	0	0	124	2	0.0	1.0
	Total	162	3	1	0	0	166	4	0.0	-
Oarai R&D Center (South Wing)	Center staff	38	8	0	0	0	46	3 ^{*4}	0.1	0.7
	Other than Center staff	274	11	1	0	0	286	8	0.0	1.1
	Total	312	19	1	0	0	332	11	0.0	-

*4 For these 2 facilities, the unit is mSv/person. Since the dosimeters used are evaluated in units of 0.1 mSv, the first decimal place is rounded off and the value is entered as an integer.