

Table 1: Exposure of workers at nuclear reactor facilities for power generation (FY2022)

Plant	Attribution	Effective dose level distribution (mSv per person)									Collective effective dose (person Sv)	Average effective dose *1 (mSv)	Maximum effective dose (mSv)
		0.1 or less	over 0.1 and up to 1	over 1 and up to 2	over 2 and up to 5	over 5 and up to 10	over 10 and up to 15	over 15 and up to 20	Over 20	Total (persons)			
Tomari	Power Company	473	0	0	0	0	0	0	0	473	X	X	X
	Subcontractor	839	3	0	0	0	0	0	0	842	0.00	0.0	0.2
	Total	1,312	3	0	0	0	0	0	0	1,315	0.00	0.0	
Onagawa	Power Company	605	4	0	0	0	0	0	0	609	0.00	0.0	0.2
	Subcontractor	3,688	273	36	34	20	3	0	0	4,054	0.47	0.1	10.8
	Total	4,293	277	36	34	20	3	0	0	4,663	0.47	0.1	
Higashi Dori	Power Company	260	0	0	0	0	0	0	0	260	X	X	X
	Subcontractor	392	3	0	0	0	0	0	0	395	0.00	0.0	0.2
	Total	652	3	0	0	0	0	0	0	655	0.00	0.0	
Fukushima Daiichi	Power Company	769	362	119	106	50	6	0	0	1,412	1.13	0.8	11.84
	Subcontractor	3,921	2,046	963	1,298	966	492	216	0	9,902	23.29	2.4	17.60
	Total	4,690	2,408	1,082	1,404	1,016	498	216	0	11,314	24.42	2.2	
Fukushima Daini	Power Company	366	5	0	0	0	0	0	0	371	0.00	0.0	0.26
	Subcontractor	952	40	0	0	0	0	0	0	992	0.02	0.0	0.79
	Total	1,318	45	0	0	0	0	0	0	1,363	0.02	0.0	
Kasiwazaki-Kariwa	Power Company	1,087	13	0	0	0	0	0	0	1,100	0.01	0.0	0.18
	Subcontractor	3,023	488	55	0	0	0	0	0	3,566	0.26	0.1	1.70
	Total	4,110	501	55	0	0	0	0	0	4,666	0.27	0.1	
Hamaoka	Power Company	676	3	0	0	0	0	0	0	679	0.00	0.0	0.53
	Subcontractor	1,445	165	14	8	0	0	0	0	1,632	0.11	0.1	4.98
	Total	2,121	168	14	8	0	0	0	0	2,311	0.11	0.0	
Shika	Power Company	354	0	0	0	0	0	0	0	354	X	X	X
	Subcontractor	608	5	0	0	0	0	0	0	613	0.00	0.0	0.3
	Total	962	5	0	0	0	0	0	0	967	0.00	0.0	
Mihama	Power Company	355	3	0	0	0	0	0	0	358	0.00	0.0	0.3
	Subcontractor	1,495	150	2	1	0	0	0	0	1,648	0.07	0.0	2.5
	Total	1,850	153	2	1	0	0	0	0	2,006	0.07	0.0	
Takahama	Power Company	527	68	2	0	0	0	0	0	597	0.04	0.1	1.3
	Subcontractor	2,596	750	162	147	56	2	0	0	3,713	1.49	0.4	11.4
	Total	3,123	818	164	147	56	2	0	0	4,310	1.53	0.4	
Ohi	Power Company	394	61	1	1	0	0	0	0	457	0.03	0.1	2.7
	Subcontractor	1,804	717	190	160	23	1	0	0	2,895	1.29	0.4	11.3
	Total	2,198	778	191	161	23	1	0	0	3,352	1.32	0.4	
Shimane	Power Company	484	6	0	0	0	0	0	0	490	0.00	0.0	0.5
	Subcontractor	2,208	189	12	7	0	0	0	0	2,416	0.13	0.1	3.9
	Total	2,692	195	12	7	0	0	0	0	2,906	0.13	0.0	
Ikata	Power Company	360	16	0	0	0	0	0	0	376	0.01	0.0	0.5
	Subcontractor	1,129	235	37	28	7	0	0	0	1,436	0.30	0.2	8.0
	Total	1,489	251	37	28	7	0	0	0	1,812	0.31	0.2	
Genkai	Power Company	572	39	3	2	0	0	0	0	616	0.03	0.0	4.8
	Subcontractor	2,108	724	222	152	32	2	0	0	3,240	1.39	0.4	12.5
	Total	2,680	763	225	154	32	2	0	0	3,856	1.42	0.4	
Sendai	Power Company	461	41	1	1	0	0	0	0	504	0.02	0.0	2.2
	Subcontractor	1,493	558	119	57	12	0	0	0	2,239	0.72	0.3	7.7
	Total	1,954	599	120	58	12	0	0	0	2,743	0.74	0.3	
Tokai	Power Company	335	0	0	0	0	0	0	0	335	0.00	0.0	0.03
	Subcontractor	616	0	0	0	0	0	0	0	616	0.00	0.0	0.10
	Total	951	0	0	0	0	0	0	0	951	0.00	0.0	
Tokai Daini	Power Company	414	16	0	0	0	0	0	0	430	0.01	0.0	0.31
	Subcontractor	1,764	294	25	9	1	0	0	0	2,093	0.19	0.1	5.18
	Total	2,178	310	25	9	1	0	0	0	2,523	0.20	0.1	
Tsuruga	Power Company	278	11	0	0	0	0	0	0	289	0.00	0.0	0.72
	Subcontractor	1,038	78	6	9	4	0	0	0	1,135	0.10	0.1	9.46
	Total	1,316	89	6	9	4	0	0	0	1,424	0.10	0.1	
Commercial Plant Total	Power Company	8,770	648	126	110	50	6	0	0	9,710	1.28 *2	0.1	11.84
	Subcontractor	31,119	6,718	1,843	1,910	1,121	500	216	0	43,427	29.83	0.7	17.60
	Total	39,889	7,366	1,969	2,020	1,171	506	216	0	53,137	31.11	0.6	

*1 The average dose is calculated by multiplying the total exposure dose by the total number of people x 1000 (converted to mSv) (calculation method by NRA).

*2 The collective effective dose for commercial plant power company employees is the total excepting "X", which denotes radiation levels below the detection limit.