

List of Accidents at Fukushima Daiichi Nuclear Power Station (August 2025 to January 2026)

(Excerpted from the Nuclear Facilities Information Archive (NUCIA). Publication of some items has been delayed)

Date	Location	Summary of Accident	NR*
2025 Aug. 20	Unit 1 reactor containment vessel gas management system	<p>At around 03:54 on Aug. 20, the equipment abnormality alarm sounded on the nuclide analysis device system B of the Unit 1 reactor containment vessel gas management system. The nuclide analysis device detector was replaced and monitoring once again became possible at 15:00 on Aug. 21.</p> <p>At around 00:33 on Aug. 24, the equipment abnormality alarm once again sounded on the nuclide analysis device system B. The rare gas monitor B system had failed. On investigation, it was confirmed that the rare gas monitor system B digital multi-channel analyzer (DCMA) display was showing abnormal readings. The DMCA was replaced and the function of the primary containment vessel (PCV) gas management equipment rare gas monitor system B was restored.</p>	
Aug. 21	Onsite company center, Building A rest area	A person became unwell in the rest area of Building A in the onsite company center. The person was examined at a medical facility and was diagnosed with heatstroke.	
Sep. 17	Partner company office	A worker who had finished work in the generating station complained of feeling unwell as he was being transferred to an offsite partner company office. Upon examination by a doctor at a medical facility, the worker was diagnosed with heatstroke.	

* NR: Notification required by law.